



Certificate of Conformity

Addendum

Certificate No.: SAA-192974-EA

Date of Issue: 13 November 2019

Class Description: Miniature Overcurrent Circuit-Breaker
Product Description: Miniature Circuit Breaker

Additional Models	Trade Name	Rating
DZ4706B245	PEOPLE	Ue=415V~(2P) for Australia; or 400V~(2P) for New Zealand In=6A, Icn=Ics=4500A Type B
DZ4710B245	PEOPLE	Ue=415V~(2P) for Australia; or 400V~(2P) for New Zealand In=10A, Icn=Ics=4500A Type B
DZ4716B245	PEOPLE	Ue=415V~(2P) for Australia; or 400V~(2P) for New Zealand In=16A, Icn=Ics=4500A Type B
DZ4720B245	PEOPLE	Ue=415V~(2P) for Australia; or 400V~(2P) for New Zealand In=20A, Icn=Ics=4500A Type B
DZ4725B245	PEOPLE	Ue=415V~(2P) for Australia; or 400V~(2P) for New Zealand In=25A, Icn=Ics=4500A Type B
DZ4732B245	PEOPLE	Ue=415V~(2P) for Australia; or 400V~(2P) for New Zealand In=32A, Icn=Ics=4500A Type B
DZ4740B245	PEOPLE	Ue=415V~(2P) for Australia; or 400V~(2P) for New Zealand In=40A, Icn=Ics=4500A Type B
DZ4750B245	PEOPLE	Ue=415V~(2P) for Australia; or 400V~(2P) for New Zealand In=50A, Icn=Ics=4500A Type B
DZ4763B245	PEOPLE	Ue=415V~(2P) for Australia; or 400V~(2P) for New Zealand In=63A, Icn=Ics=4500A Type B

Additional Models	Trade Name	Rating
DZ4703B345	PEOPLE	Ue=415V~(3P) for Australia; or 400V~(3P) for New Zealand In=3A, Icn=Ics=4500A Type B
DZ4706B345	PEOPLE	Ue=415V~(3P) for Australia; or 400V~(3P) for New Zealand In=6A, Icn=Ics=4500A Type B
DZ4710B345	PEOPLE	Ue=415V~(3P) for Australia; or 400V~(3P) for New Zealand In=10A, Icn=Ics=4500A Type B
DZ4716B345	PEOPLE	Ue=415V~(3P) for Australia; or 400V~(3P) for New Zealand In=16A, Icn=Ics=4500A Type B
DZ4720B345	PEOPLE	Ue=415V~(3P) for Australia; or 400V~(3P) for New Zealand In=20A, Icn=Ics=4500A Type B
DZ4725B345	PEOPLE	Ue=415V~(3P) for Australia; or 400V~(3P) for New Zealand In=25A, Icn=Ics=4500A Type B
DZ4732B345	PEOPLE	Ue=415V~(3P) for Australia; or 400V~(3P) for New Zealand In=32A, Icn=Ics=4500A Type B
DZ4740B345	PEOPLE	Ue=415V~(3P) for Australia; or 400V~(3P) for New Zealand In=40A, Icn=Ics=4500A Type B
DZ4750B345	PEOPLE	Ue=415V~(3P) for Australia; or 400V~(3P) for New Zealand In=50A, Icn=Ics=4500A Type B

For and on Behalf of
SAA Approvals Pty Ltd


SAA Approvals Pty Ltd is accredited by JAS-ANZ under ISO/IEC 17065 and declared a RECS under Qld Electrical Safety Act 2002 and Electrical Safety Regulations 2013 certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:

www.saaapprovals.com.au

JAS-ANZ



www.jas-anz.org/register



Issued: 13-11-19 192974/7